

Tender 13/2023

Honeywell Gas Pressure Regulator (Gorter Gas Valve and actuator):

| Description | Manufacturer | Type |
|-----------------------|--------------------|----------------|
| Active control valve | Gorter - Honeywell | R100S-6-600# |
| Monitor control valve | Gorter - Honeywell | R100S-M-6-600# |
| Slam-shutoff valve | Gorter - Honeywell | HSV086-6-600# |

Scope of work:

- Refurbishing the valves/actuator as new.
- Inspection of all parts for replacement/refurbishing process (submit the process in the initial report)
- Repairing or replacing any worn parts after Samra Company's approval.
- Replacing all soft goods with genuine spare parts,
- Painting the body with suitable external weather-resistance paint.
- Internal oiling as OEM specifications.

General conditions:

- Any required extra process shall be included in the offer as blasting, ultra-sonic cleaning, lathing, etc...
- The offer shall be classified into three types of repairs (A: light repair, B: medium repair, and C: heavy repair)
- Initial report shall be included describing the type of repair (A, B, or C) clearly for each valve/actuator.
- Initial inspection and Initial Report shall be offered separately.
- Revised Quotes are not acceptable after submitting the Purchase Order by Samra Company's side and Samra Company disclaims any cost of getting back the valves to Samra's site.

